



September 27, 2019

Ms. Ingrid Setzler
Environmental Director
Kansas City Board of Public Utilities
300 N 65th Street
Kansas City, Kansas, 66102

Re: Notification Regarding Groundwater Protection Standards

Dear Ms. Setzler:

This letter has been prepared on behalf of Kansas City Board of Public Utilities (BPU) to provide notification that during the July 2019 Assessment sampling event conducted at the Nearman Creek Power Station's Bottom Ash Pond, none of the parameters listed in Appendix IV of § 257.95 were detected at concentrations above their respective groundwater protection standards. Groundwater protection standards were developed in accordance with § 257.95(h) as part of the assessment monitoring program being implemented by BPU.

Sincerely,

A handwritten signature in blue ink, appearing to read "SAM".

Mr. Scott A. Martin, PE
Professional Engineer

A handwritten signature in blue ink, appearing to read "B. Hoyer".

Mr. Brian Hoyer, PG
Project Manager

BRH/brh